



TERMINALS

PIGGY BACK DISCONNECTS

ITEM #	AWG	SIZE SPEC	MATERIAL	QTY/PACK	PACKS/CASE	COLOR
TPBP-R25-B	22-16	0.25	PVC	1,000	10	Red
TPBP-B25-B	16-14	0.25	PVC	1,000	10	Blue
TPBP-Y25-B	12-10	0.25	PVC	500	10	Yellow

Installation Instructions

- 1) Strip wire insulation 1/4"
 - 2) Insert stripped wire into terminal
 - 3) Crimp tightly using crimping tool
- Stranded copper wire only

PVC Insulation

600V
75°C

UL Listed

**premium.
industrial.
products.**